

Cypress Sweeps Chimney Service

13525 Paseo Terrano
Salinas, CA 93908
CA. Lic. 920383 (831) 642-0402

Customer Ramon James Kristl
Address 1281 Hilby
City SEASIDE State CA Zip _____
Phone (_____) _____ - _____
E-mail _____
Date 6-12-14 Time _____
Directions to Home _____

14-284

2482714

- Type of Fireplace: Prefab Masonry
- No. of Stories: (1) 2 3 4 ● No. of Fireplaces: (1) 2 3 4
- Woodstove: Insert Freestanding Pellet/Corn
- Type of Wood Used: Soft Hard Wet Dry
- Last Cleaned: _____ Year(s) Ago Never
- Number of cords burned per season: _____
- Flue Size: 8" x 8" 8" x 13" 13" x 13" 8" x 17"
 13" x 17" 6" Round 8" Round _____
- Outside Chimney Dimensions: 26" x 20"
- Fireplace Opening Size: 32" x 26"
- How did you hear about us? TV Radio Website
 Newspaper Yellow Pages Direct Mail
 Referral Repeat Customer Other

CONDITION REPORT

	Satisfactory	Unsatisfactory	Not Applicable
CHIMNEY			
1. Height <u>44"</u>	X		
2. Chimney Cap / Spark Arrestor		X	
3. Crown / Wash	X		
4. Brickwork / Mortar	X		
5. Flashing	X		
6. Flue Liner	X		
7. Moisture Resistance	X		
FIREPLACE			
8. Smoke Chamber	X		
9. Damper <u>open</u>	X		
10. Firebox / Grate	X		
11. Ash Container			X
12. Spark Screen / Doors			X
13. Tools / Gloves			X
14. Hearth Protection <u>F 20" B 16"</u>	X		
15. Misc.:			
WOODSTOVE OR FIREPLACE INSERT			
16. Stovepipe Condition (woodstove)			X
17. NFPA Approved Flue Connection			X
18. Installation / Thimble / Clearances			X
OTHER SAFETY CONSIDERATIONS			
19. Fire Ext. / Smoke Detectors / CO Alarms			X
20. Gas / Oil Furnace Flue Liner			X
21. Fire Escape Plan			X

COMMENTS: Height of Chimney is non-conforming, Pre-existing.

#2) no spark arrestor / chimney cap on flue.

CUSTOMER VERIFICATION

I have read this form and now understand which areas of my chimney system appear to be satisfactory and which areas are not satisfactory.

Signed _____ Date 6/12/14

NEXT SERVICING SCHEDULED

on June day 2015, at _____ time

The National Fire Protection Association Standard states the fireplace and chimney should be inspected yearly for any structural faults.

Chimney Professional's Signature [Signature]

RECEIPT / INVOICE

DESCRIPTION	PRICE
Inspect/Sweep flue and firebox.	145-
PO # 1007	/
SUBTOTAL	
DATE COMPLETED <u>6-12-14</u>	TOTAL <u>145.00</u>

Note: This sheet is the result of a visual inspection done at the time of cleaning. It is intended as a convenience to our customer, not as certification of fire worthiness or safety. Since conditions of use and hidden construction defects are beyond our control, we make no warranty of the safety or function of any appliance and none is to be implied.